

# Danish Indoor Climate Labelling

## Certificate no. 099



*Danish Indoor Climate Labelling hereby certifies that the product group*

**Paroc acoustic ceiling system  
with visual or not visual grid system**

*manufactured by*

**Paroc AB  
Bruksgatan 2  
S- 541 86 Skövde**

*has been approved and awarded a labelling licence*

*The declared indoor-relevant time-value has been determined  
according to the labelling criteria listed in the following documents  
issued by the Danish Indoor Climate Labelling:*

*Testing and Labelling Criteria for  
Wall and ceiling systems, 4<sup>th</sup> edition, 2007  
and General Labelling Criteria, 5<sup>th</sup> edition, 2007*

*The certificate is based on tests of Parafon Classic*

*The certificate is valid 5 years from:*

**12<sup>th</sup> March 2017**

*and is subject to annual renewal by attestation of the Schedule 1-099  
to this certificate according to the procedures of  
Danish Indoor Climate Labelling.*

*Danish Indoor Climate Labelling may withdraw the rights to use this  
Certificate in case the company does not meet the requirements.*

*This certificate can also be found at: [www.teknologisk.dk/DIM](http://www.teknologisk.dk/DIM)*

For Danish Indoor Climate Labelling

Certification Manager

Date

14.12.2017

# Danish Indoor Climate Labelling Certificate no. 099



## Schedule 1-099

**Certificate Holder:**  
Paroc AB  
Bruksgatan 2  
S-541 86 Skövde

Particle emission including fibres is classified in three classes

Category	Limits (mg/m <sup>2</sup> )	Accept
Low	$X \leq 0.75$	Yes
Medium	$0.75 < X \leq 2$	Yes
High	$2 < X$	No

*The certificate was first issued on:*  
12<sup>th</sup> March 2012

### Labelling Licence Basis:

*Danish Indoor Climate Labelling:* Testing and Labelling Criteria for Wall and ceiling systems, 4<sup>th</sup> edition, 2007. The maximum acceptable time-value for ceiling systems is determined as 60 days. The certificate applies to products considered to be identical with the tested product regarding indoor climate characteristics as specified by the labelling criteria.

Particle emission is determined by sedimentary dust of particles including fibres, which might cause irritation of the skin or the eyes, nose and upper airways in the initial period of use of the product. Products under this certificate are classified as **low**.

### Product Characteristics:

The certificate and the declared indoor-relevant time-value comprise exclusively the product group characteristics in relation to odour and irritation of the eyes, nose and upper airways. The declared indoor-relevant time-value is determined on basis of the results of chemical analyses as well as sensory evaluations. Declared time-value:

**10 days**

### Product information Requirements:

The holder of the certificate is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor climate in practice: product specifications, a list of trade names covered by the certificate, guidelines for projecting, transport, storage, assembly, limitation of applications, cleaning and maintenance.

### Monitoring and Renewal of Labelling Licence:

*Danish Indoor Climate Labelling* monitors and exercises control in accordance with its procedures in force at any time. The certificate is valid only in combination with the present schedule stating the dates of first issue, renewal and expiration, and signed by the Certification Manager of *Danish Indoor Climate Labelling*.

The application for renewal of the labelling licence filed by the certificate holder has been considered according to the requirements of the *Danish Indoor Climate Labelling* with a satisfactory result:

Labelling licence date of renewal	28.02.2017	12.09.2017	10.09.2018		
Attestation of latest renewal					
Labelling licence date of expiry	11.09.2017	11.09.2018	11.09.2019		

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.


**Tillæg B: Handelsnavne omfattet af mærkningstilladelsen**

<b>PARAFON Products</b>	<b>Edge</b>	<b>Thickness (mm)</b>	<b>Density (kg/m<sup>3</sup>)</b>
BASS	A	50-100	40
BULLER (Natur, White, Black, Grey)	A	30-100	40-48
BULLER BEVEL	B	40-50	70-120
BULLER SOLID	A	50	70-100
CLASSIC	A, E	15-40	70-120
CLASSIC COLORTONE	A	15-40	70-90
CLEAN	A, E	15-40	70-120
CLINIC	A, E	15/40	70-90
CORRIDO	A	18	70-80
DECIBEL BARRIER	A	40	120-150
DECIBEL LIGHT	A, E	40	120-150
DECIBEL MUTE	A	55	135
DECIBEL MASS	A, E	53	140
DECIBEL BOX	-	40	120
DECIBEL 35	A/E	39	150
DECIBEL 40	A	18	70
DECIBEL 41	A	39	140
DECIBEL 42	A,E	39	140
DIRECT	A	40	70
EXCLUSIVE	A, B, C, D, D2, E	15-40	70-170
EXPANDED METAL CASSETTE	A	50	40
HYGIENE	A	18-40	70-90
NORDIC	A, E	15-40	70-120
PALETTE	A, B, C, D, D2, E	15-40	70-170
PERFORATED STEEL CASSETTE	A	50	40
PRIME	A	18-40	70
REFLEX	A	18	90
ROYAL	A	30-50	70-90
ROYAL BAFFLE	A	50	70-90
SINGEL	A	40	140
SLUGGER	A	18-40	70-100
STEP DIRECT	A	18-55	100
STEP FOR GRIDS	E	18-50	100
WALL PANEL	A	40	100
VITAL	A	12-40	70

For Dansk Indeklima Mærkning

For Paroc AB

1019-18 *[Signature]*  
Dato – underskrift2018-09-10 *[Signature]*  
Dato – underskrift